

DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAŌʻA STREET, SUITE 20 • HILO, HAWAIʻI 96720 TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I HILO, HAWAI'I

ADDENDUM NO. 1

MATERIAL BID NO. 2024-12 INVITATION FOR BIDS FOR THE

FURNISHING AND DELIVERING WAIMEA WATER TREATMENT PLANT CHEMICAL INJECTORS

DISTRICT OF SOUTH KOHALA County of Hawai'i – State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

- I. Changes to **PROPOSAL**:
 - Page P-2, Item 1, **REVISE** the following:
 - o "Saf-T-Flo HC-100-A-A-4-0-E high corrosion resistance retractable chemical injection quill with 1" valve x ½" tube and integrated check valve rated for 250psi, for use with caustic soda, phosphate and ammonia solution with FHB-CLR-050-P-E FHA-CLR-050-P-E flexible hose assembly. Flexible hose assembly shall include a true union ball valve, polypropylene hose barbs, braid reinforced vinyl hose, stainless steel hose clamps and MNPT FNPT outlet or equal by approval."
- II. Changes to **SPECIAL PROVISIONS:**
 - Page SP-22, Section 222.05.A.1., **REVISE** the following:
 - o "The inlet side shall be sized to fit a 1/2" FHB-CLR-050 P-E FHA-CLR-050-P-E clear braided PVC reinforced vinyl flexible hose assembly with EPDM seal and PVC true union ball valve inlet."

BY AUTHORITY OF THE DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I

Date:	October 29, 2024	By: Yoks 1
		Keith K. Okamoto, P.E., Manager-Chief Engineer

Please sign and return immediately to the Manager-Chief Engineer of the Department of Water Supply.

Receipt of a copy of **ADDENDUM NO. 1** for MATERIAL BID NO. 2024-12, INVITATION FOR BIDS FOR THE FURNISHING AND DELIVERING WAIMEA WATER TREATMENT PLANT CHEMICAL INJECTORS, District of South Kohala, County of Hawai'i, State of Hawai'i, is hereby acknowledged.

	<u> </u>	NAME OF BIDDER	
Date:	Ву:		