

DEPARTMENT OF WATER SUPPLY • COUNTY OF HAWAI'I

345 KEKŪANAŌʻA STREET, SUITE 20 • HILO, HAWAIʻI 96720 TELEPHONE (808) 961-8050 • FAX (808) 961-8657

DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I HILO, HAWAI'I

ADDENDUM NO. 2

JOB NO. 2023-1230

INVITATION FOR BIDS

FOR THE

PARKER #4 DEEPWELL REPAIR
DISTRICT OF SOUTH KOHALA

County of Hawai'i - State of Hawai'i

The following revisions and changes shall be made a part of the contract bidding documents:

A) Changes to **PROPOSAL**:

a) Page P-8, Part "B", Item 10, <u>REVISE</u>. Cable wire gauge shall be amended from #1/0 AWG to #1 AWG.

B) Changes to **SPECIAL PROVISIONS**:

- a) Page SP-53, Section 304.05, Part A.6.c.i.a)vi)a))iv)), **REPLACE** existing requirement with the following:
 - iv)) Insulation material and certifications per IEEE 1017.2, latest.
- b) Page SP-53, Section 304.05, Part A.6.c.i.a)vi)a))vii)), **DELETE**.
 - vii)) Compliance with NEC
- c) Page SP-76, Section 304.05, Part B.9.a.i., **REPLACE** existing requirement with the following:
 - i. The cable shall comply in every respect to the IEEE 1017.2, latest edition with exception for requirements specifically defined within these specifications.
- d) Page SP-77, Section 304.05, Part B.9.b.ii.a), **REPLACE** existing requirement with the following:
 - a) Conductor insulation shall be premium grade ethylene propylene diene monomer (EPDM) in conformance with IEEE 1017.2 (latest edition). The cable insulation shall be 100% non-conductive.

BY AUTHORITY OF THE DEPARTMENT OF WATER SUPPLY COUNTY OF HAWAI'I

Date: February 14, 2025	By: A LICY
	Keith K. Okamoto, P.E., Manager-Chief Engineer
Diagracian and voturn immediately to	the Manager-Chief Engineer of the Department of Water Supply.
1 10	NO. 2 for JOB NO. 2023-1230, PARKER #4 DEEPWELL County of Hawai'i, State of Hawai'i, is hereby acknowledged.
	NAME OF BIDDER
Date:	By: